

✓ Voting Day Accessibility Checklist ✓

The purpose of this checklist is to allow you, the chief election inspector, to quickly assess whether or not your polling place has barriers for people with disabilities on Election Day. If you identify barriers, you should inform the municipal clerk so the barrier can be addressed as soon as possible. Many barriers can be easily addressed on Election Day*.

Parking

For polling locations that have parking lots:

- The accessible space(s) are clearly marked with the standard accessible parking sign.
- The accessible space(s) are located nearest to the accessible entrance.
- There is at least one van accessible space.
- There is an accessible way to get from the parking lot to the sidewalk.
- The parking lot is paved.

For polling locations that do NOT have parking lots:

- There is an accessible passenger drop-off area, or temporary on or off street accessible parking that could be designated on Election Day.

Accessible parking must be kept clear of snow, piles of leaves or other obstacles to persons with disabilities to be accessible.

*This checklist does not identify all barriers that a person may face at the polls. Answering positively to the checklist does not mean a polling site is in compliance with such laws as the Americans with Disabilities Act (ADA).

Pathways to the Building

- The path to the accessible entrance is clearly marked with large print signs if it is different from the primary route to the building.
- The path of travel is free of breaks and edges and is clear of debris such as snow, ice and leaves, and low-hanging objects such as tree branches.
- The path of travel has the necessary curb cuts and ramps so that a person using a mobility device could access the building with ease.
- All ramps have handrails (and edge protection), if necessary.
- The path of travel is well-lit when necessary.

Entrance to the Building

- The entrance to the building is free of steps or has a ramp or elevator.
- The accessible entrance to the building is unlocked.
- The accessible entrance to the building has an automatic door opener or a call button, or there is someone stationed at the door to open it.

Travel within the building

- The accessible route to the voting area is clearly marked with large print signs if it is different from the main route and/or if it is not immediately inside the accessible entrance.

Travel within the building, continued.

- Interior doors along the accessible route are unlocked and either have automatic doors or are propped open.
- If there are stairs to get to the voting area, there is an accessible elevator available.
- Hallways are well-lit and free of low-hanging objects and items protruding from the wall or sitting on the floor.
- All rugs and mats along the accessible route have low pile and are securely fastened (or removed).

Voting Area

- Instructions for voting are printed in **Large Print** (18 point font or larger) and displayed in a convenient and obvious location.
- The path of travel in the voting area is wide enough for an individual using a mobility device to navigate and turn around with ease (minimum of 5x5 feet).
- There is a table, counter or voting booth that is extra wide at the bottom (at least 36 inches), and at good height (between 28 and 34 inches) to allow someone who uses a mobility device to use it comfortably and reach all parts of the voting equipment.
- Election inspectors are trained in using and explaining the accessible voting equipment to voters.

Voting Area, continued.

- There is a plan in place to identify when a voter wants to vote curbside, and election inspectors are aware of the curbside voting policy.
- Election inspectors are aware of the special needs of voters with disabilities and are willing to provide reasonable accommodations when requested.
- The polling site has the following:
 - ✓ Signature guide or ruler to assist someone to sign their name in a straight line.
 - ✓ Communication cards or pen/paper to communicate with someone who is deaf or hard of hearing.
 - ✓ Magnifying glass to be used by someone with a sight impairment.
 - ✓ Extra seating and a policy to allow voters who have trouble standing or walking to wait to vote and maintain their place in line.

Your municipal clerk will have more detailed information about accessibility rules and laws. Additional information that may be helpful includes:

Wisconsin State Elections Board Polling Place Accessibility Survey Form: <http://elections.state.wi.us/>

U.S. Department of Justice ADA Checklist for Polling Places: <http://www.usdoj.gov/crt/ada/adahom1.htm>

This checklist was created by Disability Rights Wisconsin (DRW) and reproduced by the State Elections Board with permission of DRW. If you have questions about this checklist or about accessibility, you can contact the State Elections Board at 866-VOTEWIS (866-868-3947) or DRW at 608/267-0214 or 888/758-6049 (TTY). People with disabilities can also contact DRW if they have questions or concerns. Our toll free line for consumers and family is 800/928-8778.